

Fire Lane Sign Requirements Information Packet

City of Greer Fire Department



Updated July 2004


If you have any questions or comments regarding the information contained within; or of you need assistance interpreting these requirements, please contact

**City of Greer Fire Department
Fire Marshal's Office
103 W. Poinsett Street
Greer, South Carolina 29650
Tel: (864) 848-2169
Fax: (864) 848-2172**

FIRE LANE SIGNS

Dimension

The “No Parking Fire Lane” sign shall be 12 inches wide and 18 inches high.



Characteristics

The signs are to be all-season durable with red lettering on a white background.

Where Required

“No Parking Fire Lane” signs are required in areas that meet the following criteria:

- Fire department access roadways **20 to 26 feet in width**- Signs shall be posted on both sides as a fire lane.
- Fire department access roadways more than **26 feet in width**- Signs shall be posted on one side of the road as a fire lane.

Installation

The NO PARKING signs shall be installed as follows:

- One at the beginning of the restriction (one arrow pointing towards the restriction zone).
- One at the end of the restriction (one arrow pointing back into restricted zone).
- One at least every 200ft within the restricted area (double arrow pointing in each direction, to indicate the continuing restriction).
- Spaced evenly within the restriction (for straight curbs/zones).
- Spaced so that at least one readable sign is visible in front of a parked vehicle from any point along the restriction (for curved curbs/zones and areas that may present visual obstacles).
- Set at an angle of no fewer than 30 degrees and no more than 45 degrees with the lane of traffic flow visible from approaching traffic (curved curbs/ zones).

Some areas may need additional fire lane signs. Check with the City of Greer fire marshal office for any additional requirements.

Painting of Curbs or Streets

The City of Greer Fire Department does permit fire lanes to be painted with curb markings (see diagram for requirements).





Either type may be used provided the same type is used consistently.



←200 ft.→

←200 ft.→



Curb Painting Diagram.