



Memorandum

To: Brandy Blake

From: Scott Keeley, Fire Marshal

Re: Standard Commercial PAC Fire Comments

I have reviewed the plan submitted for the above meeting and have the following comments:

1. Need a site plan showing fire hydrant locations.
2. Need underground fire line plan for fire sprinkler system (If required).
3. Fire hydrants must be installed and in service before construction permits will be released. Fire hydrants shall be 3way with a 5" Storz connection on the pumper outlet.
4. All weather roads must be installed before construction and maintained until final paving is completed.

Submit requested plans in a PDF format to skeeley@cityofgreer.org